

## SPCC MONTHLY INSPECTION CHECKLISTS

Date: \_\_\_\_\_

Inspector: \_\_\_\_\_

Signature: \_\_\_\_\_

### Oil Storage Tank(S) Monthly Inspection

Industry Standard Consideration: STI SP001

Instructions: This section is to be completed for each aboveground oil storage tank, generator, drum, and mobile tank listed in Table 3-1.

► **Completed inspections are to be placed in Appendix B of the SPCC Plan.**

	List inspected Tank(s):			List inspected Tank(s):		
Item for Inspection	Yes	No	Descriptions and Response	Yes	No	Descriptions and Response
Exterior surfaces show signs of leakage.						
External coatings are bubbled, cracked, or damaged.						
Tanks are rusted, pitted, or deteriorated.						
Bolts, rivets, or seams are damaged, cracked, or rusted.						
Welds are cracked or non-uniform.						
Tank supports are deteriorated or buckled.						
Gauges and alarms are not working.						
There is standing water around the tank.						
Valves are leaking or deteriorated.						
Vents and pressure release devices are obstructed.						
Liquids have accumulated in spill containment area or interstitial space of AST.						
Valves, piping, and appurtenances show signs of leaking or are in disrepair.						