

## ILS-350 Weekly "Self-Test" Results TDOT Knoxville - Used Oil USTs

<b>Location:</b>	<b>Contact:</b>
<b>Tank No:</b>	<b>Phone:</b>

**Self-Test Procedure:**

- (1) Observe Veeder Root display and record.
- (2) Press "Test" button. Wait for screen display to return and record.

Date	Display Reads <i>"All FUNCTIONS NORMAL"</i>		Comments (if display does not read <i>"ALL FUNCTIONS NORMAL"</i> , record message below and call TDOT POC)	Initials
	Before Test	After Test		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		
	Yes / No	Yes / No		